

**Schena, Cristeen**

---

**From:** Aram Varjabedian <avarjabedian@woodardcurran.com>  
**Sent:** Friday, November 06, 2015 4:28 PM  
**To:** david.burns@state.ma.us; Turin, David; Joyce, Ryan (FWE); jsullivan@town.hull.ma.us; Dow, James  
**Cc:** Frank Cavaleri; Kevin Stetson  
**Subject:** FW: 245 Nantasket Ave - SSO Notification  
**Attachments:** 245 nantasket ave.jpg; Hull MA0101231 SSO form 110615.pdf

SSO form is attached, forgot to attach this in previous email.

---

**From:** Aram Varjabedian  
**Sent:** Friday, November 06, 2015 4:20 PM  
**To:** 'david.burns@state.ma.us'; 'Turin, David'; 'Joyce, Ryan (FWE)'; 'jsullivan@town.hull.ma.us'; Dow, James  
**Cc:** Frank Cavaleri; Kevin Stetson  
**Subject:** FW: 245 Nantasket Ave - SSO Notification

To All: Please find the completed SSO form for today's event. Should you have any questions, please don't hesitate to contact me.

Aram

---

**From:** Aram Varjabedian  
**Sent:** Friday, November 06, 2015 2:38 PM  
**To:** 'david.burns@state.ma.us' <[david.burns@state.ma.us](mailto:david.burns@state.ma.us)>; 'Turin, David' <[Turin.David@epa.gov](mailto:Turin.David@epa.gov)>; 'Joyce, Ryan (FWE)' <[ryan.joyce@state.ma.us](mailto:ryan.joyce@state.ma.us)>; 'jsullivan@town.hull.ma.us' <[jsullivan@town.hull.ma.us](mailto:jsullivan@town.hull.ma.us)>  
**Cc:** Dow, James <[jdow@town.hull.ma.us](mailto:jdow@town.hull.ma.us)>; Kevin Stetson <[kstetson@woodardcurran.com](mailto:kstetson@woodardcurran.com)>  
**Subject:** 245 Nantasket Ave - SSO Notification

Good Afternoon:

This SSO notification is for 245 Nantasket Ave [by Mezzo Mare' restaurant] A 6-inch PVC sewer line was broken, while National Grid was performing gas line excavation work last night at approximately 6:00pm.. The Hull Sewer Department was notified this morning at approximately 9:50am. Staff were dispatched to the location to inspect & evaluate. The 6-inch gravity sewer line had been patched last night by the excavating crew to minimize/stop any sewage from leaking into the excavated hole. A permanent repair was done by Hub Construction this morning, after notification.

No estimation of sewage can be made, since we were not notified last evening, but the amount appears to be minimal.

A complete SSO Notification form will be completed and forwarded.

Sincerely,

Aram Varjabedian

Aram Varjabedian  
Plant Manager  
Hull Wastewater Treatment Facility  
1111 Nantasket Avenue |Hull, MA 02045  
Phone 781.925.0906 | Fax 781.925.3056 | Cell 339.214.8334  
[www.woodardcurran.com](http://www.woodardcurran.com)



COMMITMENT & INTEGRITY DRIVE RESULTS